



Analysis Report

District Level Water Analysis Laboratory

Uttar Pradesh Jal Nigam, Rural, 100 H-Block, Gujaini, District
Kanpur Nagar, Pin- 208022



TC no. - 16962

Rept No.	1	Date	29-04-2026	Page No.	1
Customer Details					
Customer Name and Address	Vinyas public school , Amilhiha, Chaubepur, Kanpur nagar				
Ref Letter No. & Date	-				
Sampling Method ISO 17614 (Part - 1):2021	Sample Discription - Tubewell				
Basic Details of Sample					
District	Kanpur Nagar	Block	Chaubepur		
Gram Panchayat	Amilhiha	Village	Amilhiha		
Habitation	-	Location	Vinyas public school , Amilhiha, Chaubepur		
Water Source	RO water	Sample Code	01		
Quality of Sample	Normal/Acitic	Date of S.C.	27-04-2026		
Receiving Date	28-04-2026	S. Collector	Dinesh Kumar varma		
Sample Depositor	Dinesh Kumar varma				
Analysis Start Date	29-04-2026	Analysis Completion Date			
Technical Data of Analysis					
S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	pH @25°C	7.14	6.5-8.5	6.5-8.5	IS 3025 (Part II): 2023 (Electrometric Method)
2	Turbidity (NTU)	2.23	1.00	5.00	IS 3025 (Part I): 2023 (Nephelometer Method)
3	TDS, mg/l	80.41	500	2000	IS 3025 (Part I): 2023 (Gravimetric Method)
4	Chloride (as Cl), mg/l	10	250	1000	IS 3025 (Part 3): 2023 (Titration Method)
5	Total Alkalinity (as Na ₂ CO ₃), mg/l	20	200	600	IS 3025 (Part 23): 2023 (Titration Method)
6	Total Hardness (as CaCO ₃), mg/l	12	200	600	IS 3025 (Part 21): 2023 (Titration Method)
7	Calcium (as Ca), mg/l	6	75	200	IS 3025 (Part 40): 2023
8	Magnesium (as Mg), mg/l	2.67	30	100	IS 3025 (Part 46): 2023
9	Sulphate (as SO ₄), mg/l	10.23	200	400	APHA 24 th Ed 2023, 4500-SO ₄ (E. Turbidimetric Method)
10	Nitrate (as NO ₃), mg/l	2.43	45	No Relaxation	APHA 24 th Ed 2023, 4500-NO ₃ (B. Ultraviolet Spectrophotometric Screening Method)
11	Fluoride (as F), mg/l	0.023	1.0	1.5	APHA 24 th Ed 2023, 4500-F (C. Ion Selection Electrode Method)
12	Iron (as Fe), mg/l	0.10	1.0	No Relaxation	APHA 24 th Ed 2023, 3500-Fe (B Phenanthroline Method)
13	Colour	5	SHU	LSHU	APHA 24 th Ed 2023 Colour Method (Platinum cobalt Visual Comparison):2017
14	Taste	-	Qualitative	-	IS 3025 (Part 08): 2023
15	Odour	-	Qualitative	-	IS 3025 (Part 05): 2018

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.
5. Test performed at 25 ± 3°C temperature and 50 ± 15% relative humidity.

Prepared by
Archana Kumari

Authorized Signatory
(Archana Kumari)
Quality/Technical Manager
Contact No. → +91 - 7561920301

VARUN KATIYAR
MANAGER
VINYAAS PUBLIC SCHOOL
AMILIHA CHAUBEPUR
KANPUR

End Of Report

SHAILA VALI
PRINCIPAL
VINYAAS PUBLIC SCHOOL
AMILIHA, CHAUBEPUR
KANPUR



PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1

Dated: 29/04/2026

It is certified that an inspection team headed by Archana Kumari (Quality Manager)(Name of Officers with designation) from U.P. Jal Nigam Kanpur Nagar(Name of Department/ Office) inspected the Vinyaas Public School Amiliha, Chaubepur(Name & Address of the school) on 29/04/2026 (date of inspection) and found that the
29/04/2027 Vinyaas Public School (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.The above is valid for a period of 29/04/2027Signature with Seal: A

Name

: Archana Kumari

Designation

: Quality ManagerName & Address of the Office / Department : U.P. Jal
Nigam Kanpur Nagar

To

Vinyaas Public School.Amiliha, Chaubepur, Kanpur

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

No. 16/12/20
VARUN KATIYAR
MANAGER
VINYAAS PUBLIC SCHOOL
AMILIHA CHAUBEPUR
KANPUR

Shaila Vali
SHAILA VALI
PRINCIPAL
VINYAAS PUBLIC SCHOOL
AMILIHA, CHAUBEPUR
KANPUR